

Section 402.3: Natural ventilation thru adjoining space

- 6'x7' opening = 42 s.f. > (210 s.f. x 8% = 16.8 s.f.) and min. 25 s.f. O.K.
- Total openable area: 5'x5'/2 + 4'x5'/2 + 4'x5'/2 = 32.5 s.f.
- Openable area 32.5 s.f. > (196 s.f. + 210 s.f.) x 4% = 16.24 s.f. O.K.
- Natural ventilation for room 2 through room 1 is acceptable.

